

EASE EQUIPMENT ANCHORAGE & SEISMIC ENGINEERING

FOLLETT CORPORATION

110FB400A & 110FB400W DISPENSER

DES. R. LA BRIE

JOB NO. 11-0407

DATE 2/3/04


SHEET

1

OF 1 SHEET

SEISMIC ANCHORAGE

UPPER FLOOR



LOADS: PER 2001 CALIFORNIA BUILDING CODE - SECTION I632A (WORKING LOADS, NOT ULTIMATE)

WEIGHT = 374 LBS

HORIZONTAL FORCE (V_H) = $0.94W$ = 352 LBS

VERTICAL FORCE (V_V) = $0.33(V_H)$ = 117 LBS

BOLT FORCES:

TENSION (T)

$$T_{\text{SIDE TO SIDE}} = \frac{352\#(37.55") - (374\# - 117\#)11.24"}{2(22.76")} = 227 \text{ LBS/BOLT}$$

$$T_{\text{FRONT TO BACK}} = \frac{352\#(37.55") - (374\# - 117\#)11.74"}{2(23.56")} = 216 \text{ LBS/BOLT}$$

$$T = 227\# + 216\#(0.3) = 292 \text{ LBS/BOLT (MAX)}$$

SHEAR (V)

$$V = \frac{352\#(11.52")}{2(22.76")} = 89 \text{ LBS/BOLT (MAX)}$$

NOTE:

PROVIDE FLOOR STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN.
(BY ENGINEER OF RECORD FOR THE BUILDING)

